

**ADDENDUM NUMBER 1**  
**BIG PASCO INDUSTRIAL CENTER ENTRYWAY SIGNAGE OREGON AVE**  
**PROJECT NO. E18-01**  
**January 9, 2018**

**Bids Due: 10:00 AM, January 17, 2018**

\*\*\*\*\*

The following addendum is hereby issued and made a part of the specifications for the Big Pasco Industrial Center Entryway Signage Oregon Ave project.

- 1) Sign contractor is responsible for all design of all footings, structural elements and fabrication of sign. Design shown is for intent only of look of finished product, materials and general dimensions.
- 2) The 12x12 wide flange beam does not receive any finish.
- 3) The thickness of the aluminum panels shall be fabricated from 1/4" thick material.
- 4) The thickness of the aluminum letters shall be fabricated from 1/4" thick material.
- 5) For stud mounted aluminum panels and letters, spaces shall be maximum length of one inch offset from the corteen steel.
- 6) All painted aluminum features shown on drawings shall have a baked enamel or powder coated finish.
- 7) The color for the "Port of Pasco" aluminum panel shall be determined by the following: Pantone PMS 289 (HEX 003263); CMYK C=100, M=60, Y=0, K=56; RGB R=0, G=50, B=99.

**NOTICE** is hereby given that this addendum must be signed and enclosed with the sealed bid for the Big Pasco Industrial Center Entryway Signage Oregon Ave as evidence that the bidder has familiarized himself with all changes incorporated herein.

\_\_\_\_\_  
Name of Bidder Company

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Printed Name



\_\_\_\_\_  
Tracy Friesz  
Facilities Engineer