

ADDENDUM NUMBER 2
TRI CITIES AIRPORT INDUSTRIAL PARK BPA LIGHTING REPLACEMENT
PROJECT NO. E10-07
February 3, 2010

Bids Due: 2:00 PM, February 8, 2010

The following addendum is hereby issued and made a part of the specifications for the Tri Cities Airport Industrial Park BPA Lighting Replacement project.

1. Add to Specifications Section under "Division 1 Description of Work", the following paragraph: "Contractor shall hang all light fixtures by chain at buildings 69, 85 and 102 with a 24 inch space between the top of the light fixture and structure above (all T5 fixtures) to allow access to the ballast for replacement from the top of the fixture. The T8 fixtures at building 201 can be mounted to structure directly."

NOTICE is hereby given that this addendum must be signed and enclosed with the sealed bid for the Tri Cities Airport Industrial Park BPA Lighting Replacement as evidence that the bidder has familiarized himself with all changes incorporated herein.

Name of Bidder Company

Signature

Printed Name



Tracy Friesz
Facilities Engineer