

**ADDENDUM NUMBER 1**  
**TRI CITIES AIRPORT TERMINAL BLDG BOILER REPLACEMENT PHASE 2**  
**PROJECT NO. E10-06**  
**January 22, 2010**

**Bids Due: 10:00 AM, February 9, 2010**

\*\*\*\*\*

The following addendum is hereby issued and made a part of the specifications for the Tri Cities Airport Terminal Bldg Boiler Replacement Phase 2 project


- 1) In the Specifications Section under Division 1 in the second paragraph change the following sentence from "Contractor shall connect new boilers into existing Heat Timer Mini-Mod Modulating Sequencing control module as required" to "Contractor shall connect new boilers into existing Heat Timer Mini-Mod Modulating Sequencing control module and re-program as required".

**NOTICE** is hereby given that this addendum must be signed and enclosed with the sealed bid for the Tri Cities Airport Terminal Bldg Boiler Replacement Phase 2 as evidence that the bidder has familiarized himself with all changes incorporated herein.

\_\_\_\_\_  
Name of Bidder Company

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Printed Name

  
\_\_\_\_\_  
Tracy Friesz  
Facilities Engineer